

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

Order No. 78-62

NPDES PERMIT NO. CA0037648

ORDER AMENDING ORDER NO. 74-95  
TO ADOPT AMENDED WASTE DISCHARGE  
REQUIREMENTS FOR:

CENTRAL CONTRA COSTA SANITARY DISTRICT  
CONTRA COSTA COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region,  
(hereinafter called the Board) finds that:

1. The Board on September 17, 1974, adopted Order No. 74-95 (NPDES No. CA0037648) prescribing waste discharge requirements for Central Contra Costa Sanitary District, hereinafter called the discharger.
2. Discharge Prohibition D.2. of Order No. 74-95 prohibits discharge above 30 million gallons per day (mgd).
3. Discharger has requested in a letter dated April 19, 1978, that the flow limit of Discharge Prohibition D.2 be increased from 30 mgd to 35 mgd.
4. Discharger has installed interim equipment modifications which provide 35 mgd treatment capacity.
5. Review of recent monitoring data has shown that the treatment plant is in substantial compliance with waste discharge requirements.
6. The amendment of waste discharge requirements for this discharge is exempt from the provisions of Chapter 3 (commencing with Section 21000) of Division 13 of the Public Resources Code in accordance with Water Code Section 13389.
7. The discharger and interested agencies and persons have been notified of the Board's intent to revise requirements for the existing discharge and have been provided with the opportunity to submit their written views and recommendations.
8. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED that Discharge Prohibition D.2 of Order No. 74-95 is amended to read as follows:

"The average dry weather flow shall not exceed 35 mgd as determined over a 3 month consecutive period."

I, Fred H. Dierker, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on August 15, 1978.

FRED H. DIERKER  
Executive Officer